



# RESTRICTED ITEMS REGISTER



## Cardan shaft brakes



**Before being allowed to operate on a Fletcher site, all vehicles (including contractors) with cardan shaft parking brake systems must:**

- be identified with cardan shaft decals displayed
- be inspected, and provide evidence that NZTA Form 4085D has been completed
- carry a copy of the NZTA 4085D form in the vehicle at all times

- carry and use wheel chocks when parked and / or the vehicle is left unattended.

Additional controls required for approved use:

- Drivers must be taken through the Worksafe NZ Technical Bulletin: Driveshaft parking brake failures in commercial and industrial vehicles. Scan the QR code.

## Ladders



**Step, straight and extension ladders are only to be used to access and egress areas at height (not to be worked from unless managed by a Permit to Work).**

Alternatives for consideration:

- Podium / platform ladders
- MEWP
- Scaffold (mobile, fixed).

Additional controls required for approved use:

- Short duration tasks in an environment that podium ladders cannot be used (<5 minutes)
- Ladder not to exceed 4:1 ratio
- Ladder must be secured top / bottom or by person.

## Powder actuated tools



High and low velocity

**Powder actuated tools are known to be high-risk, with potential to cause serious injury.**

Alternatives for consideration:

- Makita GN 900 Gas Framing nailer 50-90mm.

Additional controls required for approved use:

- Review Worksafe guidance include and include controls listed in JSEA.

## Scaffold

Internal ladder hatch

*Note: this restriction does not apply to mobile scaffolds*



**Fall from height is a known risk around internal ladder access openings. There are multiple situations where safer alternatives are available.**

Alternatives for consideration:

- Separate stairs bay.
- Separate ladder access bays and gates.

*Competent scaffold companies will be able to advise on best alternatives for your situation.*

Additional controls required for approved use:

- Hatches or equivalent should only be used as a last resort where no other access is possible (i.e. access into tank or room where space is restricted).
- The risk of falling must be communicated to all people using the scaffold and ensure they are aware of the need to close the hatch after each use.



**Scan this QR code  
for more details  
on restricted items**